

## Lexington Pit Rehabilitation Phase 1 Contractor Questions

*Some of the source areas look to have old asphalt mixed in; is Overton to remove these piles prior to the contract or are they to be used in the shaping?*

- The miner (OSG) has agreed to remove all piles, etc. that are not clean sand, including the source areas with asphalt mixed in. Asphalt and other encountered debris will not be used in the shaping.

*Is there more information RE previous dynamiting at the OSG pit? Specifically, where and when parts of the site had been dynamited?*

- OSG said the west portion of the pit where work is being conducted was blasted and is safe. The blasting contractor confirmed he has blasted a good portion of the west side of the pit. The EDO can coordinate a meeting between the selected contractor, OSG, and the blasting contractor prior to work beginning to ensure that work conditions are safe. Additional blasting can take place if deemed necessary.