



**PLATTE RIVER RECOVERY IMPLEMENTATION PROGRAM
P25-016: Lexington Pit Rehab Phase 2**

Updated February 10, 2026

1) Is fence removal in the scope of work?

No, separate fencing contractors will remove fence prior to construction.

2) Are contractors required to be MSHA compliant?

No, contractors are not required to be MSHA compliant.

3) What is the minimum buried depth for trees and organic material?

All organic material and trees must be buried at least 36 inches below finished grade.

4) Can trees be buried without being burned?

We anticipate that trees can be buried without being burned, provided there is still sufficient cover (min. 36") below finished grade. If volume of trees is too large to fit with sufficient cover, then burning will be required.

5) How deep is the open water surrounding the project site?

Approximately 30 feet deep.